

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
13D Mirza Ghalib Street, Kolkata 700016**

Memo No : IND/WB/FES/20182019/46972

DATE: 21/04/2019

From :
The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :
SOUTH POINT HIGH SCHOOL
South Point High School
82/7A Ballygunge Place
Gariahat F.S., Gariahat,
Kolkata - 700019 .

Sub :Renewal of Fire Safety Certificate for the occupancy of a G+V & G+II Storied under group Educational Building in the name of "South Point High School" at the premises No.- 82/7A Ballygunge Place, Gariahat, Kolkata - 700019.

This is in reference to your Application No. IND/WB/FES/20182019/46972, dated 21/04/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of a G+V & G+II Storied under group Educational Building in the name of "South Point High School" at the premises No.- 82/7A Ballygunge Place, Gariahat, Kolkata - 700019..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
- 2.The Interior finish decoration of building shall be made with low flame spread material

confirming to the I.S. Specification.

- 3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- 4.Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
- 5.Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
- 6.If required the old electrical line shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 7.Emergency Lighting system (Battery Backup) to be installed in the staircase for the save equation:
- 8.The Fire Check Door (if any) shall be sealed with rubber sealing properly in order to prevent percolation of smoke.
- 9.First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 10.All the pumps and detection systems which are incorporated in the building shall be kept in auto mode round the clock
- 11.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
- 12.Periodical flashing of water in the Hydrants & Sprinkler Pipe line shall be made to maintain the efficient working performance of above mention system.
- 13.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 14.A Fire control room including a closed circuit T.V. system will have to be installed which observes all floors of the buildings.
- 15.A crew of trained Fireman under experienced officer shall be maintained round the clock for safety of the building.
- 16.The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- 17.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.
- 18.The notice for validation of Fire Safety Certificate of the building, Fire Fighting and Evacuation from the building shall be prepared and displayed at entrance of the Building.
- 19.Existing L. P. Gas bank (if any) shall be protected with automatic sprinkler as per relevant I.S. specification. Fire License for the same shall be obtained otherwise Renewal of Fire Safety Certificate shall be treated as cancelled.
- 20.Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this fire safety certificate will be treated as cancelled.
- 21.This Renewal of 'Fire Safety Certificate' is valid for three year and has to be renewed as

per existing Govt. Rule from the date of issue of this Certificate.

22.A certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regular performance of all the life & Fire Safety arrangements and installations of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by RATAN
KUMAR HALDER
Date: 2019.04.21 14:51:12 IST