



R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS
(AN ISO 9001:2015 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR
9, BENTINCK STREET, KOLKATA - 700 001
Phone : (033) 4044-3380 / 3381 / 3382 / 3383, Fax : 33 2248-0447
E-mail : rvbriggs.kolkata@gmail.com, Website : www.rvbriggs.com
CIN : U51109WB1931PTC007007



NABL ACCREDITED
LABORATORY
Certificate No. TC-7815

TEST REPORT

ULR NO. TC781521000004113F

No. W(S)/21-22/717

Date : August 27, 2021

Page 1 of 3

Issued to : M/S, SOUTH POINT HIGH SCHOOL
82/7A, Ballygunge Place, Kolkata - 700019
Your Ref. : E-mail dtd. 17.08.2021
Sample Description : Drinking Water
Mark on Sample : Ground Floor Corridor Basin Tap
Sample Submitted by the Party On : 17.08.2021
Test Completed on : 19.08.2021

Parameters Tested:
Microbiological :
1) Coliform Organism (2) E.Coli


Microbiological Test Findings :

Sl No.	Test parameters	Test Method	Unit	Result	Norms as per IS : 10500, 2012 (2nd Rev.)
1	Coliform Organism	APHA 23rd Edn. 9222B	CFU/100ml	Absent	Absent in 100 ml
2	E. coli	APHA 23rd Edn. 9222H	CFU/100ml	Absent	Absent

Remarks on Microbiological Test Report :

The above mentioned sample of drinking water complies with IS: 10500, 2012 (2nd Rev.) & Satisfactory for drinking purpose, in respect of the above mentioned parameters.

: END OF TEST REPORT :


Dr. S. Koruri
Authorized Signatory
(I/C Microbiological Dept.)

NCB

- * The test report shall not be reproduced, except in full, without written approval of the Company.
- * Results relate only to the parameters tested.



R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS
(AN ISO 9001:2015 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Ph. : 2248-3661/2698/7803, 2262-4153/4154, Fax : 33 2248-0447

33 4007-5880/4066-1585/4600-1228/4008-4438

E-mail : rvbriggs.kolkata@gmail.com, Website : www.rvbriggs.com

CIN : U51109WB1931PTC007007



TC-7815

TEST REPORT

ULR NO. TC781522100000915F

No. W(S)/21-22/1777

Date : February 16, 2022

Page 1 of 3

Issued to

: M/S, SOUTH POINT HIGH SCHOOL

82/7A, Ballygunge Place, Kolkata - 700019

Your Ref.

: Sample Order Receipt No. RVB/FM/50 Sl. No. 7724 dtd. 09.02.2022

Sample Description

: Drinking Water

Mark on Sample

: Main Building 2nd Floor Corridor

Sample Submitted On

: 09.02.2022

Test Completed on

: 10.02.2022

Parameters Tested:

Microbiological :

1) Coliform Organism (2) E.Coli


Microbiological Test Findings :

Sl No.	Test parameters	Test Method	Unit	Result	Norms as per IS : 10500, 2012 (2nd Rev.)
1	Coliform Organism	APHA 23rd Edn. 9222B	CFU/100ml	Absent	Absent
2	E. coli	APHA 23rd Edn. 9222H	CFU/100ml	Absent	Absent

Remarks on Microbiological Test Report :

The above mentioned sample of drinking water complies with IS: 10500, 2012 (2nd Rev.) & Satisfactory for drinking purpose, in respect of the above mentioned parameters.

: END OF TEST REPORT :


Dr. S. Koruri
Authorized Signatory
(I/C Microbiological Dept.)

SS

- ★ The test report shall not be reproduced, except in full, without written approval of the Company.
- ★ Results relate only to the parameters tested.